



# भारत सरकार

केन्द्रीय लोक निर्माण विभाग  
कार्यालय : सहायक अभियन्ता-III  
के.लो.नि.वि., अजमेर (राजस्थान)

दूरभाष : 0145-2620705

ई-मेल : [harish.sharma69@nic.in](mailto:harish.sharma69@nic.in)

पत्र संख्या:- 54(KV2 Ajmer)/स.अ.-11/2021/159

दिनांक 25/5/2021

सेवा में

श्रीमान् प्राचार्य,  
केन्द्रीय विद्यालय-2,  
के.रि.पु.बल, समूह केन्द्र 2, फॉयसागर रोड़,  
अजमेर


विषय :- विद्यालय भवन, चारदिवारी एवं आवासों की सुरक्षा एवं संरक्षा के संबंध में

संदर्भ:- Your Letter No. 6-7/के.वि 2/अजमेर/2020-21/ (हिं०) दिनांक 19/11/2020.

Sir,

With reference to letter under reference on the subject it is certified that the building is structurally sound and safe. Subject to the following suggestions required to be followed for up keeping the safety of the building:-

1. Plantation/Gardening near foundation should be avoided, so that seepage of water may not cause damage to foundation and flooring.
2. At terrace/Chajjas and roofs opening of rain water pipes, toilet outlets may be cleaned periodically to avoid seepage/leakage of water through roofs and walls.
3. Proper annual repair and maintenance of building be taken up.
4. The building structure is safe, except corridors in both portion for which repair & rehabilitation sanction is received & tender procedure is in process.

  
Assistant Engineer  
Ajmer Central Sub-Division-III,  
CPWD, Ajmer

Cope to :- The Executive Engineer, CPWD, Ajmer.

Assistant Engineer

  
8/6/21

जी.एस. मेहता / G.S. MEHTA  
प्राचार्य / PRINCIPAL  
के.वि.नं.-2 / K.V. No.-2  
फॉय सागर रोड़, अजमेर  
Fov Saagar Road, AJMER